

OFFICE USE ONLY

Log No. 38275
 Permit No. _____
 Basin 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18868

1. OWNER Robert Johnston ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4055 Schurz Hwy. 4055 Schurz Hwy
Fallon, Nev. 89406 Fallon, Nev. 89406

2. LOCATION NW 1/4 NW 1/4 Sec. 18 T. 18 N/S R. 29 E Churchill County
 PERMIT NO. 6-821-05 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	6	6
Coarse Brown Sand		6	19	13
Brown Clay		19	27	8
Brown Coarse Sand		27	34	7
Brown Clay		34	36	2
Fine Gray Sand		36	38	2
Black Silt		38	43	5
Coarse Black & Green Sand		43	51	8
Black Silt		51	80	29
Green & Black coarse Sand		80	92	12
Fine Gray Sand		92	96	4
Fine Green Sand		96	101	5
Green & Black Coarse Sand		101	115	14
Fine Green Sand		115	119	4
Brown Clay		119	124	5
Fine Brown Sand		124	128	4
Brown Coarse Sand	X	128	145	17

8. WELL CONSTRUCTION
 Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 145 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	145

Perforations:
 Type perforation Mill Cut
 Size perforation 1/8"
 From 141 feet to 144 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 145 feet

9. WATER LEVEL
 Static water level 19 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name PARSONS DRILLING, INC. Contractor
 Address P.O. BOX 1265 Contractor
FALLON, NEVADA 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
 Signed Douglas Parsons
 By Driller performing actual drilling on site or contractor
 Date July 20, 1992

Date started June 1992
 Date completed June 23 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

AUG 10 P 1:21
 RECEIVED BY STATE ENGINEERS OFFICE