

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21331

1. OWNER Thayne Hammond ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1780 Lattin Road 6605 Sierra Way  
Fallon, Nev. 89406 Fallon, Nev. 89406  
 2. LOCATION S/W 1/4 S/W 1/4 Sec. 18 T. 28 19 N. R. 19 28 E. Churchill County  
 PERMIT NO. 08-112-35 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material                  | Water Strata | From | To  | Thick-ness |
|---------------------------|--------------|------|-----|------------|
| Sand                      |              | 0    | 11  | 11         |
| Brown Sandy Clay          |              | 11   | 16  | 5          |
| Green Clay                |              | 16   | 21  | 5          |
| Brown Clay                |              | 21   | 42  | 21         |
| Brown Fine Sand           |              | 42   | 51  | 9          |
| Fine Green Sand           |              | 51   | 56  | 5          |
| Black & Green Coarse Sand |              | 56   | 78  | 22         |
| Black Fine Sand           |              | 78   | 95  | 17         |
| Brown Clay                |              | 95   | 97  | 2          |
| Brown Coarse Sand         | X            | 97   | 121 | 24         |

8. WELL CONSTRUCTION  
 Depth Drilled 121 Feet Depth Cased 121 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches 0 Feet To 121 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6-5/8              | 12.92               | .188                    | 0           | 121       |

Perforations:  
 Type perforation Mill Cut  
 Size perforation 1 7/8"  
 From 117 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 121 feet

9. WATER LEVEL  
 Static water level 15' 10" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Unknown

Date started August 11, 1992  
 Date completed August 11, 1992

7. WELL TEST DATA

| TEST METHOD:  | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift |        |                               |              |
|   |        |                               |              |
|   |        |                               |              |
|   |        |                               |              |
|   |        |                               |              |
|   |        |                               |              |
|   |        |                               |              |
|   |        |                               |              |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name PARSONS DRILLING, INC. Contractor  
 Address P.O. BOX 1265 Contractor  
FALLON, NEVADA 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715  
 Signed Doug Parsons  
 By driller performing actual drilling on site or contractor  
 Date August 17, 1992

RECEIVED  
 AUG 19 AM 10 47  
 STATE ENGINEERS OFFICE