WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38284
Permit No.
Basin 101

NOTICE OF INTENT NO. 20583

1. OWNER Rick Lawrence
MAILING ADDRESS 1277 Soda Lake Road
Fallon, Nev. 89406

ADDRESS AT WELL LOCATION
1277 Soda Lake Road
Fallon, Nev. 89406

2. LOCATION NE ¼ SE ¼ Sec. 20 T. 19 N/S R. 28 E. Churchill County

PERMIT NO. (Issued by Water Resources) | 008-191-15 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse Sand		0	18	18
Brown Clay		18	25	7
Fine Sand		25	30	5
Brown Clay		30	45	15
Coarse Sand		45	50	5
Gray Clay		50	71	21
Black Clay		71	73	2
Gray Caly		73	78	5
Coarse Sand	X	78	91	13
Brown Clay		91	93	2

RECEIVED JUL 21 '92 AM 10:08 STATE ENGINEER'S OFFICE

Date started July 3, 19 92
Date completed July 3, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 93 Feet Depth Cased 93 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	93 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	93

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 78 feet to 91 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 93 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NEV. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date June 7 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627