

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20968

1. OWNER DAN RODGERS ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 803 MUSTANG \_\_\_\_\_  
GARDNERVILLE, NV \_\_\_\_\_  
 2. LOCATION SE 1/4 SE 1/4 Sec 13 T. 12 N. R. 20 E. DOUGLAS County  
 PERMIT NO. 29-442-09 Parcel No. \_\_\_\_\_ Subdivision Name RHEVNSTROTH  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	16	16
SAND + GRAVEL		16	28	12
SANDY CLAY		28	73	45
CLAY		73	90	17
GRAVEL		90	96	6
GRAVEL + SANDY CLAY	✓	96	182	86
SANDY CLAY		182	195	13
SAND + GRAVEL		195	208	13
SANDY CLAY + GRAVEL		208	215	7
GRAVEL, SAND + BOULDERS	✓	215	285	70

8. WELL CONSTRUCTION  
 Depth Drilled 285 Feet Depth Cased 285 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 240 Feet  
5 7/8 Inches 240 Feet 285 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>240</u>
<u>5 9/16</u>	<u>11</u>	<u>.188</u>	<u>240</u>	<u>285</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 X 3/32  
 From 220 feet to 240 feet  
 From 240 feet to 285 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 240 feet

9. WATER LEVEL  
 Static water level 130 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD. Contractor  
FALLOON, NV  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
 Signed Pat J. Moore  
 By driller performing actual drilling on site or contractor  
 Date 7/20/92

Date started 7-9, 1992  
 Date completed 7-20, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>2</u>

92 AUG 13 AM 11:07  
 RECEIVED  
 STATE ENGINEERS OFFICE