WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.370 and NAC 534.340

OFFICE USE ONLY
Log No. 38301
Permit No.
Basin 165

NOTICE OF INTENT NO. 68943

1. OWNER Ernie Lupek
MAILING ADDRESS P.O. Box 622 Genoa, NV.
ADDRESS AT WELL LOCATION 1321 Centennial Dr. Genoa NV

2. LOCATION NW ¼ NW ¼ Sec. 3 T. 13 N/S R. 19 E. Douglas County
PERMIT NO. NA (Issued by Water Resources) 17-072-17 (Parcel No.) NA (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☑ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary
☐ Other

6. LITHOLOGIC LAB

Material	Water Strata	From	To	Thickness
Alluvial fill - brown gravel, sand & gravel	NO	185'	192'	7'
Alluvial fill "	YES	192'	225'	33'

8. WELL CONSTRUCTION
Total Depth 225 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	185 Feet
5 Inches	180 Feet	225 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	2	.172	180	225

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Gravel Packed: ☐ Yes ☐ No
From Feet to Feet

Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 175 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name KAWCHACK Drilling (Contractor)
Address Rt. #3 2668 Jubler (Contractor)
Minden, NV. 89423
Nevada contractor's license number issued by the State Contractor's Board 021268
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1533
Signed Scott Chitwood (By driller performing actual drilling on site or contractor)
Date Aug. 14th '92

Date started Aug 10th, 1992
Date completed Aug 12th, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12	None	2

'92 AUG 24 P 2:51
RECEIVED STATE ENGINEER'S OFFICE

(Rev. 12-90) (O)-627