

Log No. 33387
 Permit No. 71
 Basin 71

NOTICE OF INTENT NO. 21186

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER H.E. Hunewill Construction ADDRESS AT WELL LOCATION Sand and Gravel Pit
 MAILING ADDRESS 315 Artist View South of Winnemucca, Nevada
Wellington, Nevada 89444

2. LOCATION SE 1/4 NE 1/4 Sec. 24 T. 35 N. R. 37 E Humboldt County

PERMIT NO. 55305 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Very Large Rock, Boulders				
Fine Sand		0	65	65
Large Rock, Gravel, Sand		65	95	30
Fractured Small Rock, Sands		95	110	15
Fractured Small Rock, Mixed				
With Brown Clays		110	122	12
White, Brown, Black				
Fractured Rock With				
Brown Clays		122	155	33
Assorted Colored Fractured				
Small Rock		155	215	60
Broken, Fractured Rock		215	243	28
Round Brown Rock With				
Clay		243	273	20
Brown Clays With Broken				
Rock		273	280	7
Broken Rock With Clay				
Stringers		280	300	20
Fractured Rock		300	310	10
Assorted Colored Broken				
Fractured Rock		310	335	25

8. WELL CONSTRUCTION
 Depth Drilled 335 Feet Depth Cased 333 Feet

HOLE DIAMETER (BIT SIZE)
 From 20 Inches 0 Feet 335 Feet
 To _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	33.38	.250	+1	333

Perforations:
 Type perforation 12 inch double mill
 Size perforation slot perforation
 From +1 feet to 150 feet blank
 From 150 feet to 333 feet perf
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 51 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 51 feet to 335 feet

9. WATER LEVEL
 Static water level 85 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started August 4, 1992
 Date completed August 15, 1992

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sargent Irrigation Company Contractor
 Address 99.55 North Virginia Street Contractor
Reno, Nevada 89506
 Nevada contractor's license number issued by the State Contractor's Board 21246
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1789
 Signed Dan Plante
 By driller performing actual drilling on site or contractor
 Date August 19, 1992