WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38335
Permit No.
Basin

NOTICE OF INTENT NO. 20596

1. OWNER Tom Von Drehle
MAILING ADDRESS 736 Scott Drive
Fernley, Nevada 89408

ADDRESS AT WELL LOCATION Farm District Road
Fernley, Nevada

2. LOCATION SW ¼ SW ¼ Sec. 24 T 20 N/S R 25 E Lyon County
PERMIT NO. N/A (Issued by Water Resources) | 21-35-16 (Parcel No.) | An & Hazel Lucas (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	2	2
Gravel		2	12	10
Brown Clay		12	15	3
Gravel		15	18	3
Brown Clay		18	21	3
Gravel		21	47	26
Brown Clay		47	59	12
Coarse Sand		59	73	14
Fine Sand		73	84	9
Coarse Sand		84	89	5
Fine Sand		89	94	5
Coarse Sand	X	94	114	10
Brown Clay		114	115	1

'92 AUG -6 A11:08 RECEIVED STATE ENGINEERS OFFICE

Date started July 20, 1992
Date completed July 21, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 115 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	115

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	115

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 111 feet to 114 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 115 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NEVADA 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date July 31, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627