

*Hugging*  
 STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 38344  
 Permit No. 87  
 Basin. 87  
 NOTICE OF INTENT NO. 16389

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Reno Sparks Convention & Visitors Aut. ADDRESS AT WELL LOCATION  
 MAILING ADDRESS Post Office Box 837 3500 Sullivan Lane  
Reno, Nevada 89504-0837 Sparks, Nevada 89431  
 2. LOCATION NW 1/4 NE 1/4 Sec. 32 T. 20 N/S R. 20 E. Washoe County  
 PERMIT NO. W-302B Wildcreek Golf Course  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt, Silt, Clay, Sm/Lg Gravels, Sand		0	9	9
Broken Rock, Sands, Gravels		9	120	111
Consolidated Rock		120	140	20
Consolidated Rock-Fractures		140	200	60
Black Lava Rock, Small Fractures		200	360	160
Black Lava Rock		360	403	43
WELL ABANDONED TO FULL DEPTH WITH HOLE PLUG AND CYPAN - VISCOSITY 90 SECONDS WEIGHT 10.33				

8. WELL CONSTRUCTION  
 Depth Drilled 403 Feet Depth Cased \_\_\_\_\_ Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
8 Inches 0 Feet 403 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 75  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 15 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Sargent Drilling, Inc. Contractor  
 Address 9955 North Virginia Street Contractor  
Reno, Nevada 89506  
 Nevada contractor's license number 26917  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1482  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date August 20, 1992

Date started June 10, 1992  
 Date completed August 19, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			