WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38365
Permit No.
Basin 101

NOTICE OF INTENT NO. 20597

1. OWNER Brent Ford
MAILING ADDRESS P.O. Box 1582
Fallon, Nev. 89407

ADDRESS AT WELL LOCATION
2080 Christy Circle
Fallon, Nev. 89406

2. LOCATION N/E ¼ S/E ¼ Sec. 35 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) | 08-831-60 (Parcel No.) | Micheal & Claudia Casey (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	15	15
Brown Coarse SAnd		15	19	4
Brown Clay		19	30	11
Brown Coarse Sand		30	34	4
Gray Clay		34	38	4
Gray Coarse Sand		38	43	5
Gray Clay		43	50	7
Gray Coarse Sand		50	55	5
Gray Clay		55	68	13
Gray Sand		68	93	25
Brown Clay		93	94	1
Brown Coarse SAnd	X	94	104	10
Brown Clay		104	106	2

RECEIVED OFFICE
STATE ENGINEERS
92 AUG 19 A10:48

Date started August 6, 19 92
Date completed August 6, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 106 Feet Depth Cased 106 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	106 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	106

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 100 feet to 104 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 106 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NEVADA 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons
(By driller performing actual drilling on site or contractor)

Date Aug. 10, 1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627