WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38396
Permit No.
Basin 162

NOTICE OF INTENT NO. 11063

1. OWNER Morris Kaufman
MAILING ADDRESS
ADDRESS AT WELL LOCATION Melanie Circle

2. LOCATION SE ¼ NW ¼ Sec. 34 T. 19S N/S R. 53 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) | 29-852-17 (Parcel No.) | Rancho Del Sol Lot 17 Unit 3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	11'	11'
Caliche		11'	12'	1'
Clay		12'	24'	12'
Caliche		24'	26'	2'
Clay		26'	37	11'
Caliche		37'	44'	7'
Clay		44'	54'	10'
Caliche		54'	61'	7'
Clay		61'	78'	17'
Caliche		78'	82'	4'
Clay		82'	95'	13'
Caliche	WB	95'	103'	8'
Clay		103'	117'	14'
Caliche	WB	117'	123'	6'
Clay		123'	136'	13'
Caliche	WB	136'	140'	4'

RECEIVED
JUN 16 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-28, 1992
Date completed 6-2, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0'	140'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation Sawcut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dem (By driller performing actual drilling on site or contractor)
Date 6-11-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627