

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.34

Permit No. 38470
 Basin
 NOTICE OF INTENT NO. 9657
Writz St.

1. OWNER Ellew Earley ADDRESS AT WELL LOCATION
 MAILING ADDRESS

2. LOCATION SE 1/4 NE 1/4 Sec 24 T. 20S N/S R. 5E County Nye
 PERMIT NO. N/A Issued by Water Resources Parcel No. 28-78A-14 Subdivision Name Charleston Park Ranchos Unit 6

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0'	17'	17'
Caliche		17'	22'	5'
Clay		22'	53'	31'
Caliche	WB	53'	58'	5'
Clay		58'	81'	23'
Caliche	WB	81'	87'	6'
Clay		87'	98'	11'
Caliche	WB	98'	108'	10'
Clay		108'	124'	16'
Caliche	WB	124'	136'	12'
Clay		136'	140'	4'

8. WELL CONSTRUCTION
 Depth Drilled 140' Feet Depth Cased 140' Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0' Feet
140' Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0'</u>	<u>140'</u>

Perforations:
 Type perforation Sawcut
 Size perforation 1/8 x 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 140' feet to 50' feet

9. WATER LEVEL
 Static water level 57 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 4-14, 1992
 Date completed 4-16, 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HR 78 Box 80358 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Durn
 By driller performing actual drilling on site or contractor
 Date 4-16-92

RECEIVED
 APR 21 1992
 Div. of Water Resources
 Branch Office - Las Vegas, NV