WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38425
Permit No.
Basin 162

NOTICE OF INTENT NO. 11055

1. OWNER Robert Dietz
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NW ¼ Sec. 15 T. 20S N/S R. 53 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) 35-321-16 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	48'	48'
Calichie		48'	50'	2'
Clay		50'	63'	13'
Calichie		63'	64'	1'
Sandy Clay		64'	70'	6'
Clay		70'	73'	3'
Sandy Clay		73'	81'	8'
Calichie	WB	81'	84'	3'
Clay		84'	97'	13'
Calichie	WB	97'	109'	12'
Clay		109'	119'	10'
Calichie	WB	119'	128'	9'
Clay		128'	155'	27'
Limestone	WB	155'	162'	7'
Clay		162'	175'	13'
Calichie	WB	175'	182'	7'
Clay		182'	191'	9'
Calichie	WB	191'	192'	1'
Clay		192'	200'	8'

RECEIVED
JUN 2 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-7, 1992
Date completed 5-12, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200' Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)
12 1/4 Inches From 0' Feet To 200' Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	200'

Perforations:
Type perforation Sawcut
Size perforation 1/8 x 3
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 200' feet to 50' feet

9. WATER LEVEL
Static water level 56 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, Nv. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 5-28-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627