

OFFICE USE ONLY  
 Log No. 38432  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 9697

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Grover Townsend ADDRESS AT WELL LOCATION 1771 Donner St.  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SW 1/4 NW 1/4 Sec. 17 T. 20-S N/S R. 53 E Nye Nye County  
 PERMIT NO. \_\_\_\_\_ Cal Vegas Ranchos Unit F  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material          | Water Strata | From | To  | Thickness |
|-------------------|--------------|------|-----|-----------|
| Surface           |              | 0    | 4   | 4         |
| Grey clay/caliche |              | 4    | 18  | 14        |
| Brown clay        |              | 18   | 32  | 14        |
| Grey clay/caliche | X            | 32   | 34  | 2         |
| Brown clay        | X            | 34   | 140 | 106       |

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 8 5/8              | 16.94               | .188                    | 0           | 140       |

Perforations:  
 Type perforation Torch Cut  
 Size perforation 1/4 in. width 8 in. long  
 From 1.00 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

RECEIVED  
 MAY 14 1992

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started May 1, 1992  
 Date completed May 1, 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| 20     | 4                             | 1/4          |

9. WATER LEVEL  
 Static water level 44 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Jim Pike Well Drilling Contractor  
 Address P. O. Box 56 Contractor  
Pahrump, Nevada 89041  
 Nevada contractor's license number issued by the State Contractor's Board 17563  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1324  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date May 3, 1992