


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety
 accordance with NRS 534.170 and NAC 534.140



Log No. 38467
 Permit No. _____
 Basin _____

NOTICE OF INTENT NO. 9537

1. OWNER Edwido Walden ADDRESS AT WELL LOCATION Brian St.
 MAILING ADDRESS _____

2. LOCATION SW 1/4 NW 1/4 Sec 11 T. 21S N/S. R. 53 E Nye County
 PERMIT NO. N/A 44-421-03 Tukwila Ranchos Lot 19
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0'	4'	4'
Caliche		4'	10'	6'
Clay		10'	36'	26'
Caliche		36'	40'	4'
Clay		40'	58'	18'
Caliche	WB	58'	63'	5'
Clay		63'	89'	26'
Caliche	WB	89'	94'	5'
Clay		94'	116'	22'
Caliche	WB	116'	120'	4'
Clay		120'	128'	8'
Caliche	WB	128'	140'	12'

8. WELL CONSTRUCTION
 Depth Drilled 140' Feet Depth Cased 140' Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 140' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0'</u>	<u>140'</u>

Perforations:
 Type perforation Sawcut
 Size perforation 1 1/8 x 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140' feet to 50' feet

9. WATER LEVEL
 Static water level 54 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 3-17 1992
 Date completed 3-23 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dan
 By driller performing actual drilling on site or contractor
 Date 4-20-92

RECEIVED

APR 23 1992

Div. of Water Resources
 Branch: Central Las Vegas, NV