


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



Log No. 38411
 Permit No. _____
 Basin _____

NOTICE OF INTENT NO. 11060

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Andy Devine ADDRESS AT WELL LOCATION Frite
 MAILING ADDRESS _____

2. LOCATION SE 1/4 NE 1/4 Sec 24 T. 20S N/S R 52 E Nye County
 PERMIT NO. N/A Issued by Water Resources Parcel No. 28-782-23 Subdivision Name Charleston Park Lot 122 Unit 6

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	32'	32'
Caliche		32'	35'	3'
Clay		35'	54'	19'
Caliche		54'	57'	3'
Clay		57'	84'	27'
Caliche		84'	89'	5'
Clay		89'	98'	9'
Caliche		98'	108'	10'
Clay		108'	123'	15'
Caliche		123'	134'	11'
Clay		134'	140'	6'

8. WELL CONSTRUCTION
 Depth Drilled 140' Feet Depth Cased 140' Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0' Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0'</u>	<u>140'</u>

Perforations:
 Type perforation sawcut
 Size perforation 1/8 x 3
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140' feet to 50' feet

9. WATER LEVEL
 Static water level 48 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling
 Address HCR 78 Box 80358 Pahrump, NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dam
 By driller performing actual drilling on site or contractor
 Date 6-4-92

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 JUN 10 1992
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 6-1-92 1992
 Date completed 6-4-92 1992