WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. #36070 38552
Permit No.
Basin 122

NOTICE OF INTENT NO. 16798

1. OWNER Corona Gold
MAILING ADDRESS P.O. Box 3220
Hawthorne, NV 89415

ADDRESS AT WELL LOCATION
Calvada Mine

2. LOCATION NE ¼ NW ¼ Sec. 33 T 9 N/S R 35 E Mineral County
PERMIT NO. 57486T (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
dirt/broken rock/clay/silt		0	5	5
red-brown lava rock fracture w/clay		5	110	105
dark gray lava rock/gray clay fractured		110	145	35
gray lave/gray clay		145	190	45
dark gray lava/gray clay		190	280	90
black lava rock/gray clay frac		280	355	75
black lava rock very hard		355	435	80

'92 JUN 24 A10:15
STATE ENGINEER

Date started May 26, 19 92
Date completed June 5, 19 92

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 435 feet
..... inches
..... inches
Casing record 8-5/8 steel
Weight per foot 22.36 Thickness .250

Diameter	From	To
8-5/8 inches	+1 feet	435 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 51 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 51 feet to 435 feet

Perforations:
Type perforation 8-5/8 x .250 wall slotted double perf
Size perforation
From 215 feet to 415 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 117.8 feet below land surface
Flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sargent Irrigation Company (Contractor)
Address 9955 North Virginia, Reno, NV 89506 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1540
Signed [signature] (By driller performing actual drilling on site or contractor)
Date June 19, 1992

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627