

OFFICE USE ONLY
 Log No. 3856
 Permit No. _____
 Basin 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13381

1. OWNER Hammond Homes ADDRESS AT WELL LOCATION 6600 Sierra Way
 MAILING ADDRESS 1980 Cattaraugus Rd

2. LOCATION SE 1/4 SE 22 T 18 N/S R. 28 E Churchill County
 PERMIT NO. 08-11234 Parcel No. _____
 Issued by Water Resources Subdivision Name Hammond-Schueler

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	7	7
Clay		7	62	55
Silty Sand		62	85	26
Clay		85	91	6
Sand		91	109	18

8. WELL CONSTRUCTION
 Depth Drilled 109 Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>10</u>	<u>0</u>	<u>50</u>	<u>50</u>
<u>6</u>	<u>50</u>	<u>109</u>	<u>109</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.9</u>	<u>0.188</u>	<u>+1</u>	<u>109</u>

Perforations:
 Type perforation Machine slot
 Size perforation 3/32

From _____ feet to _____ feet
 From 103 feet to 107 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 9 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 62 °F Quality _____

Date started Feb 9, 1992
 Date completed Feb 9, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>35</u>	<u>1 1/2</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Contractor
 Address Box 888 Fallon NV 89406 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772

Signed [Signature] By driller performing actual drilling on site or contractor
 Date Feb-16-92