


PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 1853



1. OWNER Emil Martini ADDRESS AT WELL LOCATION 4755 Old 395 N. Carson City, NV 89701
MAILING ADDRESS 4785 Franktown Rd. Carson City, NV 89701

2. LOCATION SW 1/4 SW 1/4 Sec. 3 T. 16N N/S R 19 E Washoe County
PERMIT NO. 55-041-14 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Yellow & White Rocks		0	20	20
Grey Clay w/granite bldr.		20	40	20
Granite		40	140	100
Fractured Granite	x	140	180	40
Hard Fractured Granite	x	180	240	60
Some Clay with Fractures	x	240	300	60
White Clay and fractured granite w/ some gravel	x	300	365	65

8. WELL CONSTRUCTION
Depth Drilled 365 Feet Depth Cased 365 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>12 1/2</u>	0	180
<u>8</u>	180	365

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>		<u>.188</u>	<u>0</u>	<u>180</u>
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>165</u>	<u>365</u>

Perforations:
Type perforation: Factory
Size perforation: .050 x 3"

From	To
<u>140</u> feet	<u>160</u> feet
<u>185</u> feet	<u>190</u> feet
<u>210</u> feet	<u>215</u> feet
<u>235</u> feet	<u>240</u> feet
<u>340</u> feet	<u>345</u> feet

Surface Seal: Yes No Seal Type:
Depth of Seal: 100' Neat Cement
Placement Method: Pumped Poured Cement Grout Concrete Grout

Gravel Packed: Yes No
From 100 feet to 180 feet

9. WATER LEVEL
Static water level 34 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 60 °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. Contractor
Address P.O. Box 888 Contractor
Fallon, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772

Signed [Signature]
By driller performing actual drilling on site or contractor
Date 2-1-'92

Date started 1-10 1992
Date completed 2-1 1992

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50+</u>	<u>30</u>	<u>3</u> hours