WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38661
Permit No.
Basin 89

NOTICE OF INTENT NO. 18532

1. OWNER Emil Martini
MAILING ADDRESS 4785 Franktown Rd.
Carson City, NV 89701

ADDRESS AT WELL LOCATION
4755 Old 395 N.
Carson City, NV 89701

2. LOCATION SW ¼ SW ¼ Sec. 3 T 16N N/S R 19E E Washoe County

PERMIT NO. (Issued by Water Resources) | Parcel No. 55-041-14 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the 6 5/8" domestic well that was 110' deep. We first perforated the casing from bottom to about 20' where we were unable to perforate due to probable cement seal. We cut the casing down 2' below grade and pumped neat cement from bottom to the top using approximately 2 yards cement. The perforations were made with a "Mills Knife factory perforator. Static water level was approximately 55' from top of casing at the time of abandonment.				

'92 FEB 24 P12:49 RECEIVED STATE ENGINEERS OFFICE

Date started 2-19, 19 92
Date completed 2-19, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal X
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 55' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MacKay Pump & Geothermal, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1719

Signed R. Bruce MacKay (By driller performing actual drilling on site or contractor)
Date 2-19'92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627