WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38663
Permit No.
Basin 89

NOTICE OF INTENT NO. 17710

1. OWNER Bailey Construction
MAILING ADDRESS 790 La Rue Ave
Reno, NV

ADDRESS AT WELL LOCATION 2090 Buckskin
New Washoe City

2. LOCATION NE ¼ NE ¼ Sec. 31 T. 17 N/S R. 20 E. Washoe County

PERMIT NO. ____ Issued by Water Resources | 50-365-11 Parcel No. | New Washoe City #5 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden, Sand		0	10	10
Firm D.G.		10	83	73
Hard, fine grain blue-gray granite w/ fractures		83	193	110
Granite w/ fracture 2 GPM flow	✓	193	197	4
Hard granite w/ fractures, no H2O		197	220	23
Sand Stone, Very Hard		220	245	25
Course Sand Stone, weathered w/ water	✓	245	258	13
Hard fractured granite		258	265	7
T.D. 265'				

Date started JAN 27, 19 92
Date completed Feb 3, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blew 10 GPM from 260'		

8. WELL CONSTRUCTION
Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 1/4 Inches		0 Feet	60 Feet
9 7/8 Inches		60 Feet	265 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.3	.188	+2	265

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 245 feet to 265 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 60 feet to 265 feet

9. WATER LEVEL
Static water level 87 feet below land surface
Artesian flow 10 G.P.M. ____ P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address Carson City, NV 89701 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1544

Signed Larry Hoch (By driller performing actual drilling on site or contractor)
Date 2/4/92

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627