WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38669
Permit No.
Basin 92B

NOTICE OF INTENT NO. 10833

1. OWNER PAUL ROMERO
MAILING ADDRESS 426 Roberts Street, Reno, NV 89502
ADDRESS AT WELL LOCATION Oregon & Idaho 960 Idaho, Reno, NV 89506

2. LOCATION NW ¼ NE ¼ Sec. 15 T 21N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 80-414-09 (Parcel No.) Lemmon Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	4	3
Brown sand		4	6	2
Brown sandy clay		6	69	63
Soft zone		69	71	2
Brown sandy clay		71	168	97
Soft zone (NO WATER)		168	173	5
Brown sandy clay		173	208	35
Soft zone	X	208	219	11
Brown sandy clay		219	227	8
Soft zone	X	227	236	9
Soft sandy clay		236	247	11

Date started 2-20-92, 19
Date completed 2-21-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 247 Feet Depth Cased 247 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	247 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	247

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 247 feet

9. WATER LEVEL
Static water level 155 feet below land surface
Artesian flow 25 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date 2-25-92

92 FEB 27 AM 11:04 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627