WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38679
Permit No.
Basin 162

NOTICE OF INTENT NO. 11188

1. OWNER Edith Shaw
MAILING ADDRESS
ADDRESS AT WELL LOCATION McMurry St.

2. LOCATION SW ¼ NW ¼ Sec. 29 T. 19S N/S R. 53 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) 29-407-07 (Parcel No.) Crystal Air Est. Lot 6 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	8'	
Caliche		8'	10'	2'
Clay		10'	28'	18'
Caliche		28'	30'	2'
Clay		30'	48'	18'
Caliche		48'	50'	2'
Clay		50'	60'	10'
Caliche	WB	60'	62'	2'
Clay		62'	78'	16'
Caliche	WB	78'	80'	2'
Clay		80'	108'	28'
Caliche	WB	108'	110'	2'
Clay		110'	122'	12'
Caliche	WB	122'	124'	2'
Clay		124'	134'	10'
Caliche	WB	134'	136'	2'
Clay		136'	140'	4'

RECEIVED
AUG 07 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started July 26th, 1992
Date completed July 30th, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0'	140'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation Sawcut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, Nv. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1770
Signed Steve Scearce
By driller performing actual drilling on site or contractor
Date 8-3-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627