WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

In Book

OFFICE USE ONLY
Log No. 38690
Permit No.
Basin 162

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8662

1. OWNER O.M. Gullard
MAILING ADDRESS 6022 S. Euclid Ave
Las Vegas, Nv 89120

ADDRESS AT WELL LOCATION Off Murphy on Hardy
Pahrump, Nv 89041

2. LOCATION SW ¼ SW ¼ Sec. 13 T. 20 N/S R. 52 E. Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. Unit 1-136 Subdivision Name Charleston Pk Ranchos

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	8	8
Sticky Br. Clay		8	15	7
Brown Clay		15	30	15
Soft Br Clay	x	30	33	3
Hard Br Clay		33	35	2
Lt Br. Clay		35	80	45
Sandy Br Clay	x	80	84	4
Hard Br Clay		84	86	2
Br Clay		86	110	24
Soft Sandy Clay	x	110	115	5
Br Clay		115	140	25

Date started 5-28, 19 92
Date completed 6-2, 19 92

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
JUN 29 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

BAILER TEST
G.P.M. 25 Draw down 12 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 8 inches Total depth 140 feet
inches
inches
Casing record
Weight per foot Thickness 188

Diameter	From	To
8 inches	0 feet	141 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement-Grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 140 feet

Perforations:
Type perforation Factory Cut
Size perforation 1/8 x 3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 40 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name O.M. Gullard Drilling Co. (Contractor)
Address 6022 S. Euclid Ave - L.V., NV 89120 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4796
Nevada contractor's driller's number issued by the Division of Water Resources 115
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed O.M. Gullard (By driller performing actual drilling on site or contractor)
Date 6-22-92

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627