



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11125

1. OWNER Daniel Chacchia ADDRESS AT WELL LOCATION Van St.
 MAILING ADDRESS _____

2. LOCATION SW 1/4 NE 1/4 Sec 24 T. 20S N/S R. 52 E Nye County
 PERMIT NO. N/A Issued by Water Resources Parcel No. 28-781-02 Subdivision Name Charleston Park Lot 82 Unit 6

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0'	4'	4'
Caliche		4'	6'	2'
Clay		6'	19'	13'
Caliche		19'	21'	2'
Clay		21'	31'	10'
Caliche		31'	33'	2'
Clay		33'	44'	11'
Caliche		44'	45'	1'
Clay		45'	56'	11'
Caliche	WB	56'	59'	3'
Clay		59'	74'	15'
Caliche	WB	74'	76'	2'
Clay		76'	93'	17'
Caliche	WB	93'	95'	2'
Clay		95'	181'	86'
Caliche	WB	181'	123'	2'
Clay		123'	134'	11'
Caliche	WB	134'	136'	2'
Clay		136'	140'	4'

8. WELL CONSTRUCTION
 Depth Drilled 140' Feet Depth Cased 140' Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 140' Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.578	16.94	.188	0'	140'

Perforations:
 Type perforation sawcut
 Size perforation 1 5/8 x 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 140' feet to 50' feet

9. WATER LEVEL
 Static water level 54 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started July 29th 1992
 Date completed Aug. 3rd 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 AUG 18 1992
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump, NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1770
 Signed Steve Searce
 By driller performing actual drilling on site or contractor
 Date 8-5-92