WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38703
Permit No.
Basin

NOTICE OF INTENT NO. 11129

1. OWNER Robert Lopez
MAILING ADDRESS
ADDRESS AT WELL LOCATION Fritz

2. LOCATION SW ¼ NE ¼ Sec. 24 T 20S N/S R 52 E Nye County
PERMIT NO. N/A (Issued by Water Resources) | 28-782-20 (Parcel No.) | Charleston Park Lot 118 Unit 6 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	4'	4'
Caliche		4'	6'	2'
Clay		6'	18'	12'
Caliche		18'	20'	2'
Clay		20'	34'	14'
Caliche		34'	36'	2'
Clay		36'	54'	18'
Caliche	WB	54'	56'	2'
Clay		56'	74'	18'
Caliche	WB	74'	77'	3'
Clay		77'	104'	27'
Caliche	WB	104'	106'	2'
Clay		106'	117'	11'
Caliche	WB	117'	119'	2'
Clay		119'	126'	7'
Caliche	WB	126'	128'	2'
Clay		128'	137'	9'
Caliche	WB	137'	139'	2'
Clay		139'	140'	1'

Date started July 28th, 19 92
Date completed Aug 3rd, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
AUG 18 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0' Feet	140' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation Sawcut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, Nv. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1770
Signed Steve Scease (By driller performing actual drilling on site or contractor)
Date 8-5-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627