WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38735
Permit No.
Basin

NOTICE OF INTENT NO. 11101

1. OWNER Robert Chavez
MAILING ADDRESS
ADDRESS AT WELL LOCATION Jackie St.

2. LOCATION NE ¼ NW ¼ Sec. 1 T. 21S N/S R. 53 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) 44-092-11 (Parcel No.) MANKO Lot 149 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	5'	5'
Caliche		5'	8'	3'
Clay		8'	25'	17'
Caliche		25'	27'	2'
Clay		27'	41'	14'
Caliche		41'	45'	4'
Clay		45'	50'	5'
Caliche		50'	52'	2'
Clay		52'	62'	10'
Caliche	WB	62'	64'	2'
Clay		64'	70'	6'
Caliche	WB	70'	72'	2'
Clay		72'	85'	13'
Caliche	WB	85'	88'	3'
Clay		88'	116'	28'
Caliche	WB	116'	118'	2'
Clay		118'	122'	4'
Caliche	WB	122'	124'	2'
Clay		124'	134'	10'
Caliche	WB	134'	136'	2'
Clay		136'	140'	4'

RECEIVED
JUL 13 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started July 4th, 19 92
Date completed July 8th, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12 1/4	0'	140'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation Sawcut
Size perforation 18 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, Nv. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1770
Signed Steve A. Scease (By driller performing actual drilling on site or contractor)
Date 7-8-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627