WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38756
Permit No.
Basin 162

NOTICE OF INTENT NO. 11283

1. OWNER Fred Cressler/Cathy Holland
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ SW ¼ Sec. 31 T. 21-S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) 44 (Parcel No.) Cal-Vista Subdivision (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	8	8
Clay/Gravel		8	16	8
Sandstone		16	40	24
Brown Clay		40	105	65
Reddish Clay	x	105	120	15
Brown Clay	x	120	192	72
Gypsum Formation	x	192	208	16
Brown Clay		208	240	32

RECEIVED
JUL 28 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started July 20, 19 92
Date completed July 22, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	240 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	18 lbs.	.188	0	240

Perforations:
Type perforation Torch Cut
Size perforation ¼ in width 8 in long
From 180 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 38 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address St. Rt. Box 36525 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg (By driller performing actual drilling on site or contractor)
Date July 22, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627