WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38757
Permit No. 55252
Basin 162

NOTICE OF INTENT NO. 3287

1. OWNER Dr. Dennis Campton
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SW ¼ Sec. 31 T. 21-S N/S R. 54 E. Nye County
PERMIT NO. 55252 (Issued by Water Resources) | 42 (Parcel No.) | Cal-Vista Subdivision (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown Clay		4	22	18
Clay / Small Gravel		22	38	16
Brown Clay		38	130	92
Shale	x	130	138	8
Brown Clay / Intermitten				
Hard Streaks	x	138	202	64
Gypsum Formation	x	202	208	6
Brown Clay		208	292	84
Broken Shale	x	292	297	5
Brown Clay		297	300	3

RECEIVED
FEB 18 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started February 7, 19 92
Date completed February 12, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	300 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	33lbs.	.250	0	300

Perforations:
Type perforation Torch Cut
Size perforation ¼in width 8 in long
From 196 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 96 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address St. Rt. Box 36525 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed (By driller performing actual drilling on site or contractor)
Date 2-13-1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627