

3

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38761
Permit No.
Basin 163

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 9005

1. OWNER B & K Construction ADDRESS AT WELL LOCATION Sandy Valley
MAILING ADDRESS

2. LOCATION SE 1/4 NE 1/4 Sec 27 T. 24 N. R. 56 E Clark County
PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Silty Sand</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>Clay</u>		<u>10</u>	<u>95</u>	<u>85</u>
<u>Brn. Clay Stone</u>	<u>X</u>	<u>95</u>	<u>140</u>	<u>45</u>

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 140
9 7/8 Inches Feet
Inches Feet
Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>7 1/2</u>	<u>140</u>

Perforations:
Type perforation Turk
Size perforation 1 1/4" X 10"
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From feet to feet

RECEIVED
AUG 21 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow 40 G.P.M. P.S.I.
Water temperature Coal °F Quality OK

Date started 7-25 1992
Date completed 7-27 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Air developed</u>			
<u>450 CFM @ 250 PSI</u>			
<u>140'</u>	<u>40 gpm</u>		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Mitchell Enterprises Contractor
Address 630 Reel Contractor
Las Vegas, NV. 89129
Nevada contractor's license number issued by the State Contractor's Board 27030
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475
Signed Dean Mitchell
By driller performing actual drilling on site or contractor
Date 7-29-92