WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38824
Permit No.
Basin 087

NOTICE OF INTENT NO. 19640

1. OWNER Steffen Robertson & Kirsten (U.S.)
MAILING ADDRESS 1755 East Plumb Lane, Suite 241
Reno, NV 89502

ADDRESS AT WELL LOCATION Buggy Bath
2525 S. Virginia
Reno, NV 89509

2. LOCATION SE ¼ NW ¼ Sec. 24 T. 19N N/S R. 19 E. Washoe County
PERMIT NO. M/O 397 MW-5 (Issued by Water Resources) Parcel No. Peppermill area (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Other Tubex 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt to 5". Clayey sand, medium grained light brown moist		0	5"	5"
Sand, with trace clay/silt, 80% medium grained, subangular brown, moist,		5"	3	3
		3	10	7
Gravelly sand, grading into small gravel at 12 feet		10	12	2
Sandy gravel, predominantly to ½" diam. subrounded brownish gray		12	19	7
Gravelly sand with considerable silt/clay predominantly medium grained, slightly plastic clay, brown		19	33.8	

Date started 03/17/92, 19
Date completed 03/18/92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 33.8 Feet Depth Cased 33.8 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 5/16 Inches		0 Feet	33.8 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5" PVC		SCH 40	0	33.8
4.5" PVC end cap				
4.5" PVC locking cap				

Perforations:
Type perforation factory sawed slot
Size perforation .020 x 1½ x 6 rows
From 18.8 feet to 33.8 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 2.6 bentonite
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
11.1

Gravel Packed: [X] Yes [ ] No
From 16.7 feet to 33.8 med. acquar sand feet

9. WATER LEVEL
Static water level 26.7 feet below land surface
Artesian flow not known G.P.M. P.S.I.
Water temperature n/k °F Quality not known

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 10, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627