

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 38836  
 Permit No. 87  
 Basin 87  
 NOTICE OF INTENT NO. 17261

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER David Keith Todd, Cons. Eng. Inc. ADDRESS AT WELL LOCATION Time-Oil  
2914 Domingo Ave. Sparks, Nevada  
Berkeley, CA 94705  
 2. LOCATION NW 1/4 NW 1/4 Sec 9 T 19N N/S R 20 E Washoe County  
 PERMIT NO. M/O 440 TO-10 Tank Farm Sparks, Nevada  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Tubex 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill material, metal debris, dark stained soil, bricks		0	2.5	2.5
Silty sand, 70% fine-med. sand, 30% silt. 2.5Y 4/2 dark greyish brown		2.5	7	4.5
Gravel/cobbles, 1/2-6" mafic, well rounded, clasts clean. < 10% sand, 2.5Y 4/2 dark greyish brown		7	27.5	20.5
Color change (brown) 2.5Y 4/4 olive brown @ 16'				
Silty sandy gravel, 70% 1/4-4" gravel, iron stained		27.5	35	7.5
Color change at 27.5' dark yellowish brown Rusty, occasional chalky clay stringers.				
Silty sandy gravel 85% 1/4-4" iron stained gravel, 10% sand 5% silt. 2.5Y 5/4 light olive brown		35	44	9
Color change at 44' (Rusty) 10YR 4/4				

8. WELL CONSTRUCTION  
 Depth Drilled 44 Feet Depth Cased 38.5 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9.5/16 Inches 0 Feet 44 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 I.D. CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		SCH 40	0	44
4" PVC end cap/centralisers				
4" PVC locking cap				

 Perforations:  
 Type perforation factory sawed slot  
 Size perforation 0.20 x 1 1/2 x 6 rows  
 From 13.5 feet to 38.5 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 2' bentonite 9.5'  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 11.5 feet to 44 #3 sand feet

Date started 8/15/91, 19\_\_\_\_\_  
 Date completed 8/15/91, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>NO TEST</u>			

9. WATER LEVEL  
 Static water level 24 feet below land surface  
 Artesian flow not known G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature n/k °F Quality not known

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc.  
 Address P.O. Box 12370, Reno, NV 89510  
Contractor Contractor  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board  
 Nevada driller's license number 908  
 issued by the Division of Water Resources, the on-site driller  
 Signed Jerry C. Helman  
 By driller performing actual drilling on site or contractor  
 Date April 8, 1992