WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38877
Permit No.
Basin 212

NOTICE OF INTENT NO. 9774

1. OWNER MOBIL OIL CORPORATION
MAILING ADDRESS 4419 N. SCOTTSDALE RD. #206
SCOTTSDALE, ARIZONA

ADDRESS AT WELL LOCATION
SWC WASHINGTON & DECATUR

2. LOCATION NE ¼ SE ¼ Sec. 25 T. 20 N(S) R. 60 E. CLARK County
PERMIT NO. WAIVER M/O-398-B
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [X] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY W/GRAVEL	N	1	15	14
CALICHE	N	15	17.5	2.5
GRAVELLY CLAY -P.C.	N	17.5	23	5.5
CLAYEY SAND	Y	23	31	8
CALICHE	N	31	?	?

RECEIVED '92 FEB 27 A11 03 STATE ENGINEERS OFFICE

Date started FEBRUARY 4, 19 92
Date completed FEBRUARY 4, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1.3	16.75	1.1

8. WELL CONSTRUCTION
Depth Drilled 32 Feet Depth Cased 32 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	32 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		SCH. 40	0	32

Perforations:
Type perforation SLOTTED SCREEN
Size perforation .020 INCH
From 32 feet to 12 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 11 FEET
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 32 feet to 12 feet

9. WATER LEVEL
Static water level 15.25 feet below land surface
Artesian flow – G.P.M. – P.S.I.
Water temperature – °F Quality –

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WT ENVIRONMENTAL CONSULTANTS
Contractor
Address 3611 W. TOMPKINS AVE.
Contractor
~~LAS VEGAS, NEVADA 89103~~
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761
Signed
By driller performing actual drilling on site or contractor
Date 2/17/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627