



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11130

1. OWNER Richard Hoff ADDRESS AT WELL LOCATION Fritz  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 NE 1/4 Sec. 24 T. 20S N/S R. 52 E Dye County  
 PERMIT NO. N/A Issued by Water Resources Parcel No. 28-782-27 Subdivision Name Charleston Park Lot 126

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0'	4'	4'
Caliche		4'	6'	2'
Clay		6'	16'	10'
Caliche		16'	18'	2'
Clay		18'	34'	16'
Caliche		34'	36'	2'
Clay		36'	57'	21'
Caliche	WB	57'	59'	2'
Clay		59'	74'	15'
Caliche	WB	74'	76'	2'
Clay		76'	92'	16'
Caliche	WB	92'	94'	2'
Clay		94'	118'	24'
Caliche	WB	118'	120'	2'
Clay		120'	140'	20'

8. WELL CONSTRUCTION  
 Depth Drilled 140' Feet Depth Cased 140' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0' To 140'  
12 1/4 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:  
 Type perforation Sawcut  
 Size perforation 18 X 3  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 140' feet to 50' feet

RECEIVED

SEP 11 1992

Div. of Water Resources  
 Branch Office - Las Vegas, NV

9. WATER LEVEL  
 Static water level 54 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality Good

Date started July 29th, 1992  
 Date completed Aug 3rd, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address HCR 78 Box 80358 Contractor  
Pahrump, NV. 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1770  
 Signed Steve Scarse  
 By driller performing actual drilling on site or contractor  
 Date 8-5-92