


Log No. **38934**

Permit No. \_\_\_\_\_

Basin **162**



1-Book

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **11999**

1. OWNER Chris Smith ADDRESS AT WELL LOCATION Slater Circle  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE 1/4 NW 1/4 Sec 15 T. 20S N/S R. 53 E. Nye County  
 PERMIT NO. 35-321-36 Lot 1 Nye County Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay		0	6	6
Clay		6	17	11
caliche		17	19	2
clay		19	49	30
caliche		49	54	5
clay		54	73	19
caliche	WB	73	78	5
clay		78	96	18
caliche	WB	96	109	13
clay		109	126	17
caliche	WB	126	134	8
clay		134	140	6

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>1.88</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Factory Saw Cut  
 Size perforation 1/2 x 3  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 ft  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  
 Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

**RECEIVED**  
  
 SEP 11 1992  
  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 8-31, 1992  
 Date completed 9-3, 1992

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL  
 Static water level 48 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address HCR 78 Box 80358 Contractor  
Pahrump NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1643  
 Signed Thomas Dan  
 By driller performing actual drilling on site or contractor  
 Date 9-3-92