

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **10416**

1. OWNER RON TAYLOR ADDRESS AT WELL LOCATION UNICORN AVE & DEARSKIN
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 NE 1/4 Sec 35 T. 20 S N/S R. 53 E NVE County CLAY
 PERMIT NO. 42-703-40 Parcel No. UNIT 3 LOT 2 Subdivision Name CALVADA VALLEY

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	6	6
CALICHE		6	15	9
CLAY		15	19	4
CALICHE		19	22	3
CLAY		22	35	13
CALICHE		35	37	2
CLAY		37	44	7
CALICHE		44	53	9
CLAY		53	57	4
CALICHE	W.B	57	64	7
CLAY		64	70	6
CALICHE	W.B	70	73	3
CLAY		73	95	22
CALICHE	W.B	95	97	2
CLAY		97	110	13
CALICHE	W.B	110	117	7
CLAY		117	130	13
CALICHE	W.B	130	134	4
CLAY		134	140	6

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 140 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 8 INCH BY 3 INCH
 From 140 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING
 Address HCR 78 BOX 80358
PATRUMP NV. 89041
 Nevada contractor's license number 30880
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Donnie Brown
 By driller performing actual drilling on site or contractor
 Date 9-8-92

Date started 9-2 1992
 Date completed 9-4 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED

SEP 14 1992

Div. of Water Resources
 Branch Office - Las Vegas, NV