


OFFICE USE ONLY
 Log No. 39001
 Permit No. 89
 Basin



NOTICE OF INTENT NO. 20183

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Bob Weise ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 7300 Franktown Road
Carson City, NV 89704
 2. LOCATION NE 1/4 SE 1/4 Sec 22 T 16 N/S R 19 E Washoe County
 PERMIT NO. M/O-531 Lightning W Ranch
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. (29) LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BLACK CLAYEY SAND (SC)		0.0	1.0	1.0
BLACK-BROWN CLAYEY SAND (SC)		1.0	4.5	3.5
BROWN CLAYEY SAND (SC)	yes	4.5	8.0	3.5
GRAY-GREEN CLAYEY SAND (SC)	yes	8.0	13.0	5.0
GRAY-BROWN CLAYEY SAND (SC)	yes	13.0	15.0	2.0

8. WELL CONSTRUCTION
 Depth Drilled 15.0 Feet Depth Cased 15.0 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8.0 Inches To 15.0 Feet
 From 0.0 Feet To 15.0 Feet
 From 0.0 Feet To 15.0 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.0	0.5	Schedule 40	0.0	15.0

Perforations:
 Type perforation Slot
 Size perforation .02
 From 2.5 feet to 15.0 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0.5 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 2.5 feet to 15.0 feet

9. WATER LEVEL
 Static water level 8.0 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 4/10 1992
 Date completed 4/10 1992

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Mark E. DeBusk Contractor
 Address 520 Edison Way Contractor
Reno, NV 89502
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1768
 Signed Mark E. DeBusk
 By driller performing actual drilling on site or contractor
 Date 5/10/92