WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39024
Permit No.
Basin 89

NOTICE OF INTENT NO. 19677

1. OWNER Gail Herlan
MAILING ADDRESS 8645 N. Marion Blvd.
Clovis, CA 93612

ADDRESS AT WELL LOCATION 2145 East Lake Blvd.
Carson City, NV

2. LOCATION NW ¼ SE ¼ Sec. 31 T. 17N N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. 50-385-03 Subdivision Name New Washoe City

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown sand		2	12	10
Soft D.G.		12	36	24
Gray sand		36	51	15
Weathered granite		51	59	8
GRay granite		59	69	10
Fracture (app 1 GPM)	X	69	70	1
GRay granite		70	205	135
Fracture (app 1 GPM)	X	205	206	1
Gray granite		206	240	34
Fracture (app 3 GPM)	X	240	241	1
Gray hard granite		241	248	7

'92 MAY -4 P1:33
STATE ENGINEER

Date started 4-27-92, 19
Date completed 4-29-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 248 Feet Depth Cased 248 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	248 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	248

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 68 feet to 78 feet
From 198 feet to 208 feet
From 228 feet to 248 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 248 feet

9. WATER LEVEL
Static water level 44 feet below land surface
Artesian flow 5 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, INc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date May 30, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627