WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39026
Permit No.
Basin 89

NOTICE OF INTENT NO. 19679

1. OWNER Bob Hilke
MAILING ADDRESS P.O. Box 811
Carson City, NV 89702

ADDRESS AT WELL LOCATION
2140 Eastlake Blvd
Carson City, NV

2. LOCATION NW ¼ SE ¼ Sec. 31 T. 17 N N/S R. 20 E. Washoe County
PERMIT NO. 4389 (Issued by Water Resources) | Parcel No. | New Washoe City, NV (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Brown Sand		3	12	9
D.G.		12	18	6
Weathered granite		18	35	17
Gray hard granite		35	55	20
Weathered granite		55	70	15
Gray hard granite		70	132	62
Fracture		132	133	1
Gray hard granite		133	205	72
Fracture		205	206	1
Gray hard granite		206	370	164
Fracture (no water)		370	371	1
Gray hard granite		371	465	94
Fracture		465	485	20
Gray hard granite		485	525	40

'92 MAY -4 P1:38
STATE ENGINEER

Date started 04/16/92, 19
Date completed 04/22/92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 525 Feet Depth Cased 525 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10	0	50
8 5/8	50	525

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		SCH .188	0	525

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 139 feet to 149 feet
From 249 feet to 259 feet
From 359 feet to 269 feet
From 469 feet to 479 feet
From 499 feet to 519 feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [x] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 525 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow 6½ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, Nevada 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 29, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627