WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39026
Permit No.
Basin 89

NOTICE OF INTENT NO. 19728

1. OWNER Bailey Const
MAILING ADDRESS 790 L a Rue Ave Reno NV. 89509
ADDRESS AT WELL LOCATION 285 N. Chellan New Washo City #5 Carson City, NV

2. LOCATION NW ¼ SW ¼ Sec. 32 T. 17 N/S R. 20 E. Washo County
PERMIT NO. (Issued by Water Resources) 50-378-06 (Parcel No.) New Washo City #5 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	25	25
Sandy Clay		25	30	5
Coirse Sandstone w/Small Clay Seams		30	-120	90
Hard to Med Hard Brown + White Clay		120	230	110'
Broken D.G + D.G Sand w/water	xxx	230	240	10
T.D 240'				

92 APR 30 P12:00 STATE ENGINEER

Date started 4-8, 1992
Date completed 4-11, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	15	2

8. WELL CONSTRUCTION
Depth Drilled 240' Feet Depth Cased 240' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
11 3/4	0	55
9 7/8	55	240

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	240'

Perforations:
Type perforation Mill slot
Size perforation 3½ X 3/32
From ____ feet to ____ feet
From 220 feet to 240 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 240 feet

9. WATER LEVEL
Static water level 100' feet below land surface
Artesian flow ____ G.P.M. 10 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H.H. Pump Co. (Contractor)
Address 5551 Hy. 50 E #3 Carson City NV. 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts (By driller performing actual drilling on site or contractor)
Date 4-14-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627