WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39030
Permit No.
Basin 103

NOTICE OF INTENT NO. 19131

1. OWNER Sam + Terri Arevalo
MAILING ADDRESS 816 Poney Express Dayton Nv. 89403
ADDRESS AT WELL LOCATION NOT Assined yet

2. LOCATION NE ¼ NW ¼ Sec. 28 T. 17 N/S R. 22 E. Lyon County
PERMIT NO. ____ Issued by Water Resources | Parcel No. 19-288-11 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand + Small Cobbles		0	25	25
Small Gravels		25	30	5
Larger Gravels	X	30	65	35
Sandy Brown Clay		65	70	5
Black + Red Lava Rock		70	105	35
Firm Sandstone w/Small Clay Seams		105	130	25
Broken Sand Stone w/Water	XXX	130	160	30
T.D. 160				

Date started 4/28, 1992
Date completed 4/29, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+	20'	2

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 3/4 Inches	0 Feet	55 Feet
9 7/8 Inches	55 Feet	160 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	160

Perforations:
Type perforation Mill Slot
Size perforation 3 1/2 X 3/32
From 140' feet to 160' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 0 feet to 55' feet

9. WATER LEVEL
Static water level 60' feet below land surface
Artesian flow ____ G.P.M. 20+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ____ Contractor
Address ____ Contractor
A & H PUMP CO.
5551 Hwy. 50 East #3
Carson City, Nevada 8970
883-0459 - 883-402
885-1889
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butt
By driller performing actual drilling on site or contractor
Date 4-29-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627