WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 39033
Permit No.
Basin 103

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14359

1. OWNER Jim Schryver
MAILING ADDRESS P.O. Box 8558 Incline Village Nv.
ADDRESS AT WELL LOCATION Cardelli Lane

2. LOCATION SE ¼ SE ¼ Sec. 32 T. 17 N/S R. 22 E. Lyon County
PERMIT NO. Issued by Water Resources | 19-521-02 Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0' | 1' | 1' |
| Clay | | 1' | 6' | 5' |
| Sand + Clay | | 6' | 25' | 19' |
| Brown Clay | | 25' | 74' | 49' |
| Coarse Sand | ✓ | 74' | 80' | 16' |
| Clay | | 80' | 90' | 10' |
| Sand + Gravel | ✓ | 90 | 112 | 22' |
| Clay | | 112 | | |

'92 APR 16 AM 11 36
RECEIVED
STATE ENGINEERS OFFICE

Date started MAR 26, 1992
Date completed APR 12, 1992

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 10 Draw down 0 feet 2½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 112 feet
inches
inches
Casing record
Weight per foot 13.77 Thickness 188

| Diameter | From | To |
|---|---|---|
| 10 inches | 0 feet | 55 feet |
| 6 inches | 0 feet | 112 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 52 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Torch Cut
Size perforation ⅛ x 3
From 100 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 68 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name VERNON CANNON JR
Contractor
Address 4555 Hwy 50 W. Silver Springs
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23317
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1455
Signed Vernon Cannon Jr.
By driller performing actual drilling on site or contractor
Date apr 13 1992

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY