WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39036
Permit No.
Basin 104

NOTICE OF INTENT NO. 19730

1. OWNER Wallace Hesse
MAILING ADDRESS 4769 Ponderosa Carson City NV.
ADDRESS AT WELL LOCATION 4769 Ponderosa C.C. NV.

2. LOCATION NW ¼ NE ¼ Sec. 32 T. 15 N/S R. 20 E. Carson County
PERMIT NO. Issued by Water Resources
Parcel No. 9-213-02
Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blow Sand		0	2	2'
Hard Pan Sand		2	25	23
Soft Sandstone		25	85	60'
Brown Clay Seam		85	90	5'
Sandstone w/ Small Clay Seams		90	145	55
D.C. Sand	xxx	145	155	10'
Sandstone	xxx	155	160	5'

T.D. 160'

'92 APR 30 P12:
STATE ENGINEERS

Date started 4-23, 1992
Date completed 4-23, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30-40	20'	2

8. WELL CONSTRUCTION
Depth Drilled 160' Feet Depth Cased 160' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 3/4 Inches	0 Feet	55 Feet
9 7/8 Inches	55 Feet	160 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	160

Perforations:
Type perforation Mill Slot
Size perforation 3 1/2 X 3/32
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 160' feet

9. WATER LEVEL
Static water level 40' feet below land surface
Artesian flow G.P.M. 30-40 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO.
Address 5551 Hwy. 50 East #3
Carson City, Nevada 89701
883-0459 - 883-4022
885-1889
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts
By driller performing actual drilling on site or contractor
Date 4-24-92

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627