WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39038
Permit No.
Basin

NOTICE OF INTENT NO. 19726

1. OWNER Charles Toya
MAILING ADDRESS 470 Foothill Gardnerville NV.
ADDRESS AT WELL LOCATION 402 Foothill Gardnerville Nv.

2. LOCATION SE ¼ SE ¼ Sec. 26 T. 12 N/S R. 19 E. Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. 19-300-23 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D.G. & Granite Boulders		0	60	60
Granodiorite Hard Grey & White		60	127	67
Fractured Granite With Water	xxx	127	160	33
Total Depth 160'				

APR 30 '92 PM 2:05 RECEIVED STATE ENGINEERS OFFICE

Date started 4-1, 19 92
Date completed 4-4, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	10	2

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
13 3/4	Inches	0 Feet	50' Feet
9 7/8	Inches	50 Feet	160 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	160'

Perforations:
Type perforation Mill Slott
Size perforation 3/32 x 3 1/2
From feet to feet
From 100' feet to 120' feet
From 140' feet to 160' feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 55 feet to 160 feet

9. WATER LEVEL
Static water level 80' feet below land surface
Artesian flow G.P.M. 30 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & H Pump Co. (Contractor)
Address 5551 Hy 50 E #3 Carson City NV. 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed Joe Butts (By driller performing actual drilling on site or contractor)
Date 4-7-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627