


OFFICE USE ONLY  
 Log No. 39040  
 Permit No. \_\_\_\_\_  
 Basin 105



NOTICE OF INTENT NO. 19419

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER CONSTRUCTION ZONE ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS GARDNERVILLE, NV 604 STAGE COACH RD,  
GARDNERVILLE, NV

2. LOCATION NE 1/4 NE 1/4 Sec 22 T 12 N3 R 20 E DOUGLAS County  
 PERMIT NO. \_\_\_\_\_ 29-432-02 RHUNSTROTH  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/GRAVEL		0	41	41
CEMENTED GRAVEL		41	49	8
SANDY CLAY w/GRAVEL		49	82	33
CEMENTED GRAVEL		82	97	15
SANDY CLAY w/GRAVEL		97	111	14
CEMENTED GRAVEL		111	127	16
SANDY CLAY w/COBBLES		127	183	56
CEMENTED GRAVEL		183	209	26
SANDY CLAY w/GRAVEL		209	255	46
GRAVEL w/SAND	✓	255	263	8
CEMENTED GRAVEL		263	278	15
GRAVEL w/SAND	✓	278	300	22

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 300 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>300</u>

Perforations:  
 Type perforation FACTORY SLOT, SINGLE  
 Size perforation 3" X 3/32  
 From 260 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 300 feet

9. WATER LEVEL  
 Static water level 15.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC. Contractor  
 Address 7780 CURRY RD. Contractor  
FALLON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Pat J. Moore  
 By driller performing actual drilling on site or contractor  
 Date 4-28-92

Date started 4-18, 19 92  
 Date completed 4-27, 19 92

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>2</u>

92 MAY -4 P 1:23  
 RECEIVED  
 STATE ENGINEERS OFFICE