

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19420

1. OWNER PETE BEEKHOF ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. BOX 2186 1943 WISEMAN LANE  
GARDNERVILLE, NV 89410 GARDNERVILLE, NV

2. LOCATION NW 1/4 NE 1/4 Sec 25 T 12 N R 20 E DOUGLAS County  
 PERMIT NO. \_\_\_\_\_ 29-092-17 RHVENSTROTH  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/BOULDERS		0	64	64
CEMENTED GRAVEL		64	97	33
SANDY CLAY w/COBBLES		97	145	48
CEMENTED GRAVEL		145	206	61
SANDY CLAY w/GRAVEL		206	228	22
CEMENTED GRAVEL		228	242	14
SANDY CLAY w/GRAVEL	✓	242	272	30
GRAVEL w/COARSE SAND	✓	272	288	16

8. WELL CONSTRUCTION  
 Depth Drilled 288 Feet Depth Cased 288 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 140 Feet  
8 3/4 Inches 140 Feet 288 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>288</u>

Perforations:  
 Type perforation FACTORY SLOT, SINGLE  
 Size perforation 3 x 3/32  
 From 248 feet to 288 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 288 feet

9. WATER LEVEL  
 Static water level 140 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 4-10, 1992  
 Date completed 4-17, 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC. Contractor  
 Address 7780 CURRY RD. Contractor  
FALLON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Pat J. Moore  
 By driller performing actual drilling on site or contractor  
 Date 4-19-92

'92 MAY -4 P 1:23  
 RECEIVED  
 STATE ENGINEERS OFFICE