WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39048
Permit No.
Basin 108

NOTICE OF INTENT NO. 19357

1. OWNER Charles STottlemeyer
MAILING ADDRESS #2 Panavista Circle Yerington Nev 89447
ADDRESS AT WELL LOCATION #2 Panavista Circle Yerington Nev 89447

2. LOCATION NW ¼ NE ¼ Sec. 13 T. 12 N/S R. 25 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 004-384-05 | Subdivision Name Panavista Estates

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay + Sand + Rock		102	111	9
Sand + Rock	X	115	117	2
Clay + Sand		117	119	2
Clay + Sand + Fractured Rock		119	130	11
Fractured Rock + White Clay		130	135	5
White Clay + Sand		135	137	2
Brown Clay + Sand		137	145	8
Lime Clay + Sand		145	151	6
White Clay + Sand		151	153	2
Brown Clay + Sand		153	162	9
Fractured Rock	X	162	178	16
Fractured Rock + Clay		178	184	6
Fractured Rock	X	184	222	38
Fractured Rock + Clay		222	232	10
Fractured Rock	X	232	234	2
Solid Rock		234	238	4
Fractured Rock	X	238	244	6
Fractured Quartz	XX	244	250	6
Fractured Rock	X	250	272	22
Fractured Rock + Clay		272	288	16
Broken Rock	XX	288	298	10
Fractured Quartz	XX	298	308	10
Fractured Rock		308	312	4

Date started April 15, 1992
Date completed April 22, 1992

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	28	24"	1/2 Hr

8. WELL CONSTRUCTION
Depth Drilled 102 - 312 Feet Depth Cased 312 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
7 7/8	102	312

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	98	312

Perforations:
Type perforation Sawed
Size perforation 1/8 x 3" 6 Rows
From 102 feet to 122 feet
From 162 feet to 182 feet
From 202 feet to 222 feet
From 242 feet to 262 feet
From 272 feet to 312 feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal —
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From — feet to — feet

9. WATER LEVEL
Static water level 56 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bybee Lane (Contractor) Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Gary Ogden (By driller performing actual drilling on site or contractor)
Date 5-1-92

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627