Hole # H#4

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39081
Permit No.
Basin 61

NOTICE OF INTENT NO. 14952

1. OWNER Dee Gold Mining Co
MAILING ADDRESS P.O. Box 1193
Elko, Nevada

ADDRESS AT WELL LOCATION Dee Gold Mining Co
33 Miles North of Carlin
Carlin Nevada 89822

2. LOCATION NW ¼ NW ¼ Sec. 3 T. 36N N/S R. 49E E. Elko County

PERMIT NO. ~~Nev 5000~~ M10-530 (Issued by Water Resources) — (Parcel No.) — (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	5	5
Brown Gray Clay		5	10	5
Clay Sand & Gravel		10	20	10
Clay w/ Little Sand & Gravel		20	30	10
Silty Sand		30	35	5
Clayey Sand		35	40	5
Silty Clay		40	45	5
Gray Silty Sand		45	50	5
Sand & Gravel		50	80	30

MAY -6 A11:28
STATE ENGINEER'S OFFICE

Date started 16 April -92, 19
Date completed 16 April -92, 19

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Lift to Clean out Screened Area only			

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10" Inches	0 Feet	80 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	PVC	SCH-40	0	80
All Flush Joint Threaded PVC				

Perforations:
Type perforation Sloted Screen
Size perforation .030
From feet to feet
From 50 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal Cement
Placement Method: ☐ Pumped ☑ Poured

Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 26 feet to 80 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eklund Drlg Co (Contractor)
Address 605 Union Pacific Way (Contractor)
Elko, Nevada 89801

Nevada contractor's license number issued by the State Contractor's Board 0030823

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1774

Signed Marc Eklund
By driller performing actual drilling on site or contractor

Date 16-April-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627