

Hook # H-5

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 39083
Permit No.
Basin 61

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15585

1. OWNER Dee Gold Mining Co ADDRESS AT WELL LOCATION Dee Gold Mining Co
MAILING ADDRESS P.O. Box 1193 33 Miles North of Carlin
Elko Nevada 89801 Carlin, Nevada 89822
2. LOCATION SW 1/4 NW 1/4 Sec. 3 T. 36N N/S R. 49E E Elko County
PERMIT NO. 110-530 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Redish Bt sand & Gravel</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>Black Clay</u>		<u>4</u>	<u>5</u>	<u>1</u>
<u>Gray Clay</u>		<u>5</u>	<u>10</u>	<u>5</u>
<u>Sand & Gravel</u>		<u>10</u>	<u>25</u>	<u>15</u>
<u>Light Gray Silt</u>		<u>25</u>	<u>40</u>	<u>15</u>

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet
HOLE DIAMETER (BIT SIZE)
From To
10" Inches 0 Feet 40 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>SCH-40 PVC</u>	<u>(Threaded)</u>	<u>0</u>	<u>40</u>

Perforations:
Type perforation Slotted PVC
Size perforation .030
From 10 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 0.2 Neat Cement
Placement Method: Pumped Cement Grout
 Poured 2' Bentonite Concrete Grout
Gravel Packed: Yes No
From 36 feet to 40 feet

9. WATER LEVEL
Static water level NO TEST feet below land surface
Artesian flow NO TEST G.P.M. P.S.I.
Water temperature °F Quality Monitor Well

Date started 17-APRIL-92, 19____
Date completed _____, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Air Lift to clean out screened Area ONLY</u>			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Frank D. Dyer Co Contractor
Address 605 Union Pacific way Contractor
Elko, Nevada 89801
Nevada contractor's license number 0030823
issued by the State Contractor's Board.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1274
Signed Mari Koblentz
By driller performing actual drilling on site or contractor
Date 17-APRIL-92

1992 MAY -6 AM 1:28
STATE ENGINEERS