Hole # H-1

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39105
Permit No.
Basin 61

NOTICE OF INTENT NO. 15588

1. OWNER Dee Gold Mining Co
MAILING ADDRESS P O Box 1193
Elko, Nevada 89801

ADDRESS AT WELL LOCATION Dee Gold Mining Co
33 Miles North of Carlin
Carlin, Nevada 89822

2. LOCATION SE ¼ SE ¼ Sec 33 T 37N N/S R 49E E Elko County
PERMIT NO ~~Nev Bond~~ M/O-530 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Fine sand		0	5	5
Clay & sand		5	25	20
Clay stone Red clay w/ Gravel		25	60	35

'92 MAY -6 AM 11:27
STATE ENGINEER

Date started 14 April 92, 19
Date completed , 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Left To Clean out Screened Area only.		

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10" Inches	0 Feet	60 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	PVC	SCH-40	0	60

All Flush Joint Threaded PVC

Perforations:
Type perforation Sloted
Size perforation .030
From 10 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0 - 8
Placement Method: ☐ Pumped ☑ Poured 2' Bentonite
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 10 feet to 60 feet

9. WATER LEVEL
Static water level No test feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eklund Drlg Co (Contractor)
Address 605 Union Pacific Way (Contractor)
Elko, Nevada 89801

Nevada contractor's license number issued by the State Contractor's Board 0030823

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1774

Signed Marc Eklund
By driller performing actual drilling on site or contractor

Date 14 April 92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627