WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39108
Permit No.
Basin 064

NOTICE OF INTENT NO. 19102

1. OWNER Eddie King
MAILING ADDRESS Star Route
Battle Mt. Nevada

ADDRESS AT WELL LOCATION At the Point
from which SE corner-Sec.10 Bares 61 06'
East 386' Battle Mt. Nevada

2. LOCATION SE ¼ SE ¼ Sec. 10 T. 32 X N/S R. 44 E. Lander County

PERMIT [redacted] 13388 (Issued by Water Resources) | 5182 certificate (Parcel No.) | - (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
[redacted] ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Exhisting Well 14" | | 0 | 140 | 140 |
| Course Sand | | 140 | 142 | 2 |
| Course Sand/ Clay | | 142 | 150 | 8 |
| Course Sand | | 150 | 160 | 10 |
| Brown Clay | | 160 | 200 | 40 |
| Course Sand | | 200 | 210 | 10 |
| Clay with short Sand and Gravel layers | X | 210 | 500 | 290 |

'92 MAY -7 P1:01
RECEIVED STATE ENGINEERS OFFICE

Date started 4/25, 19 92
Date completed 4/28, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 500 | air on Rig | 4 hrs. |

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 480 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 12 3/4 Inches | 140 Feet | 500 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.94 | .188 | +2 | 80 |

Perforations:
Type perforation Mill Slot
Size perforation 1/8 X 2
From 80 feet to 480 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow - G.P.M. - P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling and Pump Co. (Contractor)
Address P.O.Box 590 (Contractor)
Winnemucca, Nevada 89446-0590
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1713
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5-5-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627